CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



CAL

LISTING No. 3225-1721:100 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: NCA Mfg. Inc., 1985 Carroll St., Clearwater, FL 33765

Contact: Jim Meats (717) 441-2651 Fax (888) 713-3285

jmeats@metalaire.com

DESIGN: Models FSD-AF-211, FSD-AF-212, FSD-AF-231, and FSD-AF-232 fire dampers. Refer to

listee's data sheet for additional detailed product description and operational

considerations.

| F | Position | Single Section | | | | Multiple Section | | | | Rating |
|---------------|----------|----------------|------|---------------|------|------------------|------|---------------|------|--------|
| <u>Models</u> | | <u>Width</u> | | <u>Height</u> | | <u>Width</u> | | <u>Height</u> | | Hour |
| | | Min. | Max. | Min. | Max. | Min. | Max. | Min. | Max. | |
| FSD-AF-211 | V | 8" | 36" | 8" | 48" | NA | 108" | NA | 96" | 1-1/2 |
| | Н | 8" | 36" | 8" | 48" | NA | NA | NA | NA | 1-1/2 |
| FSD-AF-212 | V | 8" | 36" | 8" | 48" | NA | 108" | NA | 96" | 1-1/2 |
| | Н | 8" | 36" | 8" | 48" | NA | NA | NA | NA | 1-1/2 |
| FSD-AF-231 | V | 8" | 36" | 8" | 48" | NA | 72" | NA | 96" | 3 |
| | Н | 8" | 36" | 8" | 48" | NA | NA | NA | NA | 3 |
| FSD-AF-232 | V | 8" | 36" | 8" | 48" | NA | 72" | NA | 96" | 3 |
| | Н | 8" | 36" | 8" | 48" | NA | NA | NA | NA | 3 |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification rating, and UL label.

APPROVAL: Listed as 1½ and 3 hour fire-rated dampers. Intended for vertical or horizontal installation

in heating, ventilating and air conditioning duct systems passing through fire resistive

walls and partitions. Refer to listee's Installation Instruction Manual for details.

NOTE: Leakage rating not evaluated. Refer to Category 3230 for listed leakage dampers.

06-11-08 JW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JANUARY 9, 2009 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division